IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Craig Bell DATE 11-10-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E Broad St. To Winchester Lane

S. R. No. _____

SUBDIVISION NAME Camalot Acres LOT NO. 47 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil CcE
Percolation Rate 90 to 100 3 min/inch
Topography 10 to 20 Slope Gullied
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 20,619



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 360 Linear Ft. 320
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY Glenn Fox relay-out 11-9-78 by Acm

COMMENTS: landscape so water doesn't stand over lines & Pipe downspouts around system.

CERTIFICATE OF COMPLETION BY D. C. Moore DATE 11-10-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold