IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Andy Burch DATE 8-22-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E Broad Ext

_____ S. R. No. _____

SUBDIVISION NAME Camelot Acres LOT NO. 37 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,964 sq'

Character & Porosity of Soil AFC Prov. Suitable
Percolation Rate slow
Topography 2 to 6% Slope
Depth to Water Table 10'±
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 990 Linear Ft. 330
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Don Lackey

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 8-22-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold