IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR B. A. Daniels DATE 11-9-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad Ext.

S. R. No. _____


SUBDIVISION NAME Pemlot Acres LOT NO. 35 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	C x B	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Fast Dis Range	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 - 6% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Ample	
			Rock or other impervious formations	None	

Lot Area 22,000



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 810 Linear Ft. 270
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Lemuel Lewis & Co.

TANK FOR LOWER LEVEL
800 or
6' wide ditch
20' long -
2 LINES
10" GRAVEL

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold