IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ron Johnson DATE 6-14-96 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Broad St. Ext. Camelot Acres

S. R. No. _____


SUBDIVISION NAME Camelot Acres LOT NO. 3 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 ½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slopes Right
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25+
			Rock or other impervious formations	None

Lot Area 20,000



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 240 Linear Ft. 330

Depth of Stone in Lines _____

Water Supply: Individual ( )
Public (✓)

Installed by Yoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Fox Jr. DATE 6/14/96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold