# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ben Daniels DATE 10-25-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy E. Broad St. Ext. Chemulat

S. R. No. _____


SUBDIVISION NAME Chemulat Acres LOT NO. 6 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Res. Septic Tank

No. Bedrooms 3 No. Bathrooms 2 1/2

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes (✓) | No ( ) | Character & Porosity of Soil | @ 78 2 |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | Sla-Sand |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | 2-6% to Slope |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | unk |
| | | | Rock or other impervious formations | none |

Lot Area _____




Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 990 Linear Ft. 330

Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Ben Daniels

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Foard DATE 11/15/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold