IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Steve Fay DATE 8 Nov 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64E. approx 1 mi from I-40

S. R. No. _____

SUBDIVISION NAME Camelot Acres LOT NO. # 73 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 19,333 sq ft


Character & Porosity of Soil Red Clay

Percolation Rate Soil-Aware / average

Topography Slight slope & Rise & Fall of lot

Depth to Water Table not

Rock or other impervious formations rock



Plot of System 64E.

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 936 Linear Ft. 312
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public (✓)

Installed by Robert Hale

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wilbur M. Howard DATE 8 Nov 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold