IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dave Fay DATE 5 Feb 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Camelot Acres Lot # 75

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Sub-surface ok.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none
			Rock or other impervious formations	none

Lot Area 20,250



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 936 Linear Ft. 312
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Robert Hoke & Dave Fay

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M. Howard DATE 5 Feb 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold