IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR H. O. Dawbarn Jr. DATE 11-16-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Shannon Acres on Greenbrair Rd at end of Pavement Lot 203 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 1/2 acre +

Character & Porosity of Soil Cecil + Appling Clay
Percolation Rate 120 min/inch
Topography 2 to 6%
Depth to Water Table 10' +
Rock or other impervious formations None



Plot of System

Size of Tank 1500 + 800 Gals.
Nitrification Field:
No. of Lines 6
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: landscape & set Tile over Pump Tank So that surface water will not run into Tank.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 11-16-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold