IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hufstetler Homes DATE 2-27-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Wickersham Rd. and J St. _____ S. R. No. _____


SUBDIVISION NAME Scarborough Sect. III LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil Gravelly SaBa
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate Approved
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 6 - 10% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table Creek
			Rock or other impervious formations None

Lot Area _____



Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 500
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Donald Looney

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

The location of the proposed SHED addition does not appear to impact the existing septic system.
**NOTE: KEEP SHED MINIMUM 5' FROM SYSTEM
R. STEVE HEDRICK REHS
Date: MARCH 22 2011
ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY Steven Todd DATE 2-28-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy - White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold