IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gary L. Beaver DATE 8-5-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad St. Ext. TR into Brookmeade – Lancaster Dr.

SUBDIVISION NAME Brookmeade LOT NO. 3-4 pt SECTION OR BLOCK NO. F S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____


Character & Porosity of Soil LEBr – A5E

Percolation Rate Sat. Mud

Topography 6–10% Slope

Depth to Water Table none

Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 6
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Lacky

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Foard DATE 8/5/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold