11496

IREDELL COUNTY HEALTH DEPARTMENT

37270

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Dardeen DATE 12-13-90 PERMIT NO. 55-6-F-2

PHONE: Business _____ Home _____

LOCATION Wickersham JR Lancaster 1st lot on Rt. _____ S. R. N. _____

SUBDIVISION NAME Brookmeade LOT NO. 2 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Clayey
Percolation Rate 44
Topography Sloping
Depth to Water Table 10'
Rock or other impervious formations None

Lot Area ½ acre

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines _____
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Frazier Const Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 12-13-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold