IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Brothers DATE 7/19/79 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 64E, T.R on Bell Rd, 3rd Rt, ½ mile on left

SUBDIVISION NAME Hidden Valley LOT NO. 10 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil clay & Cecil Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	120 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10+
Lot Area ½ acre			Rock or other impervious formations	none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: System installed in adverse weather conditions

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 7/20/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold