IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mac Rice DATE 12-13-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 3306 Whickenham Dr. Lot #4

S. R. No. _____

SUBDIVISION NAME Brookmeade LOT NO. #4 SECTION OR BLOCK NO. _____


House (4) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____

Character & Porosity of Soil Red Clay (Kd)
Percolation Rate Agst. Coal Springs
Topography Slopes to left side & R.
Depth to Water Table 72"
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 990 Linear Ft. 330
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Sam Outwater

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd DATE 12/15/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold