IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roger Sloop DATE 10-29-76 PERMIT NO.

PHONE: Business Home

LOCATION Whickersham Dr. or Downy Lane

SUBDIVISION NAME Brookwood LOT NO. 8. Lot S. R. No. SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 100 x 200


Character & Porosity of Soil Clay

Percolation Rate 60 min

Topography Slight slope To Rt side

Depth to Water Table 25'

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 990 Linear Ft. 330

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by K.L. Beam

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY Steven Fox Jr. DATE 10-29-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold