11103

36507

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

55-A-90

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack King, Inc. DATE 7/3/90 PERMIT NO. A of SSA-90

PHONE: Business _____ Home _____

LOCATION E Broad, Rt on Brookmeade, Lf on Cambridge, Lot near end on Rt S. R. No. _____

SUBDIVISION NAME Brookmeade LOT NO. 4 SECTION OR BLOCK NO. III

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area 24,000+ ft²

Character & Porosity of Soil clay loam


Percolation Rate 4 spd/79°

Topography rolling

Depth to Water Table 10'+

Rock or other impervious formations none

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 18"

Water Supply: Individual ( )
Public ( )

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: (4) 25' Lengths OK by KS. Gully filled, distance to gully from line ends measured as best possible at time of inspection

CERTIFICATE OF COMPLETION BY _____ DATE 11/5/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold