IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 4-23-80 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Riverhill Rd


S. R. No. _____

SUBDIVISION NAME Quail Ridge LOT NO. 32 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 to 80 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 10%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area 1/2 acre+			Rock or other impervious formations	none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 14 to 16"

Water Supply: Individual ( )
Public (✓)

Installed by Pfaff & Sale

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 4-23-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold