TREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sherrill Farr DATE 10-21-82 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 64E TR on Bell Rd, Then TR on (2421) Hoots Rd
1/4 mile on R

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO. S. R. No.


House ✓ Mobile Home ( ) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1 1/2
Garbage Disposal Unit Yes ( ) No ✓
Auto. Dishwasher Yes ( ) No ✓
Auto. Wash. Machine Yes ✓ No ( )
Site Suitable Yes ✓ No ( )

Character & Porosity of Soil Appling clay
Percolation Rate 0-4 coff/hr/day
Topography 2 to 6% Slope
Depth to Water Table 101+
Rock or other impervious formations None

Lot Area .68 acres

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public ✓

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Divert surface water off nitrification lines

CERTIFICATE OF COMPLETION BY Terry L. Rice DATE 10-28-82

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold