IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Gregory DATE 5 July 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bell Rd. - Walden Woods Development. ½ mi on Bell Rd from 601. House on left. RD # 2421. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Front
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6'
			Rock or other impervious formations	6'

Lot Area 22,040



Plot of System RD # 2421

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 22'
Depth of Stone in Lines 0"
Water Supply: Individual (✓)
Public ( )

Installed by George Gregory

IMPROVEMENTS PERMIT BY _____

COMMENTS: 7' fall - Lay cast on end of drain line 1 foot 24"

CERTIFICATE OF COMPLETION BY William M Theard DATE 5 July 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold