IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Brothers DATE 6-26-79 PERMIT NO.

PHONE: Business Home

LOCATION 64E TR on Bell Rd 1/4 mi TR 1000' on left

SUBDIVISION NAME Hidden Valley LOT NO. 7 SECTION OR BLOCK NO. S. R. No.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 15,000 Sq'


Character & Porosity of Soil Appling + cecil clays

Percolation Rate 120 min/inch

Topography 2 to 3% Slope

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Hope Brothers

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 6-26-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold