IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

COPY

OWNER OR CONTRACTOR Hope Brothers DATE 6-26-79 PERMIT NO.

PHONE: Business Home

LOCATION 64E TRon Bell Rd 1/4 mi TR 1000' on Lft

SUBDIVISION NAME Hidden Valley LOT NO. 7 SECTION OR BLOCK NO. S. R. No.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 15,000 Sq'

Character & Porosity of Soil Appling + cecil clays
Percolation Rate 120 min/inch
Topography 2 to 3% Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Brothers

IMPROVEMENTS PERMIT BY F. C. Moore

COMMENTS: Location of the proposed 24'x24' Accessory Bldg addition does not appear to impact the existing on-site septic system.**NOTE:

Judith A Henderson REHS
Date: 11-22-13
ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY F. C. Moore DATE 6-26-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold