IREDELL COUNTY HEALTH DEPARTMENT
Phone 1164

County Building — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit Date 1-15 1949

Permit No. _____

Owner Rex B. Beaver — Address Rt. 1 Statesville

Tenant Beaver's Store — Address _____

Installed by Bass & Clifton — Address _____

Location of Property Rt 1 Beavers Store

Kind of Tank Brick — Capacity 600 — Length of trench 200


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection 1-15 1949 — Approved ✓ — Disapproved ( )

Remarks: Plans To Use Same Gravel

First five feet of line from outlet should be of cast iron soil pipe.



Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.