DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Lester Lawrence APPLICANT: 40w
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 3/30/
PROPOSED FACILITY: 3BR House/Gar PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Conv 250 Red 4 bdrm / 300
+20

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	Ridge 2%	0-24	cl mpbk						PS .3
		24-38	scl/sap mpbk						
		38-48	sap(g) lc						
2	Linear 4%	0-14	sc		24				PS .3
		14-20	sc mpbk						
		20-48	cl w/ stone/brick						
3	4% Linear	0-8	scl						PS .3
		8-18	sc mpbk						
		18-48	sc w/ stone						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	40%	40%
System Type(s)	Gravel conv.	Drip w/ 25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Lehman
OTHER(S) PRESENT: L. Lawrence