0023

DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

# SOIL/SITE EVALUATION
## for ON-SITE WASTEWATER SYSTEM

106 868
4765-48-8744

OWNER: FLEETWOOD Homes  APPLICANT: ___
ADDRESS: ___  APPLICATION DATE: ___  DATE EVALUATED: ___
PROPOSED FACILITY: D/W  PROPOSED DESIGN FLOW (.1949): ___  PROPERTY SIZE: ___
LOCATION OF SITE: EVERGREEN LOT 7  PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

| PROFILE # | .1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE | .1941 CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFIL CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | | 0-8" | scl wk gr | f ss sp scp | | | | | PS .25 |
| | | 10-36" | scl c med wk, ablc | f, ss, p, scp | | | | | |
| | | 36-48" | " w/ few distinct mottles of cromaz | " " | | | | | |
| 2 | | | SAME AS HOLE 1 | | | | | | PS .25 |
| 3 | | 0-8" | scl wk gr | f ns np scp | | | | | PS .25 |
| | | 8-24" | c, md, ablc | f, s, p scp | | | | | |
| | | 24-36" | light yellow red | f, s, p, scp | | | | | |
| | | 36 → | cromaz mixed in 8-36" | | | | | | |
| | | | description/ distinct change | | | | | | |
| | | | Stop 10" BLUE & PUT F/D | | | | | | |
| 4 | | 0-3" | scl wk gr | f ns np scp | | | | | PS .3 |
| | | 3-48" | c, md, sbk | f, s, p, scp | | | | | |

FRENCH DRAIN WILL TAKE CARE OF IT

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| Available Space (.1945) | Y | Y |
| System Type(s) | GRAV SOIL, ABS | LP PAVER |
| Site LTAR | .25 | .3 |

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: L. COOK
OTHER(S) PRESENT: J. HUDDLE