DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Heathwood Homes APPLICANT: _____
ADDRESS: Statesville NC APPLICATION DATE: _____ DATE EVALUATED: 3/20/0
PROPOSED FACILITY: 4BR MH/SF PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: .6 Acres
LOCATION OF SITE: River Hill Rd (Dan River Green @ curve) PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed (Lot # 9)

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	Linear	0-13	SL	[illegible] VFR					PS .3
		13-35	SCL w/ some [illegible]	SP SBK FR					
		35-48	SCL w/ [illegible]	SS SP SBK FR					
2	Linear	0-15	SL [illegible]	[illegible] VFR					PS .35
		15-32	SCL w/ [illegible]	CP SBK					
		32-37	SCL w/ Sap [illegible]	SS SP SBK					
		37-45	Sap [illegible]						
3	Linear	0-9	SL [illegible]	NS [illegible] NER					PS .35
		9-32	SCL w/ [illegible]	SS SP SBK					
		32-38	SCL w/ [illegible]	SS SP SBK					
		38-48	Sap [illegible]						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity Conv	50% Reduction Gravity
Site LTAR	.3	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____