DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Riverstreet LLC APPLICANT: Bob Hall
ADDRESS: P.O. Box 1732 Statesville NC APPLICATION DATE: 2-18-01 DATE EVALUATED: 2/23/01
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 440 PROPERTY SIZE: .61
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot #10 - Riverstreet

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1									
2	9% Linear	0-12	sc						PS .35
		12-16	scl	Fr SS SP SBK					
		16-37	cl mm/f mica	Fr SS SP SBK					
		37-48	cl 4typ+ f mica	Fr MP NSP					
3	8% Linear	0-4	sc cr	NS NP					PS .35
		4-9	scl mod fr	Fr SS SP					
		19-32	cl mm/f mica mod fr	Fr SS SP					
		32-44	cl mm/f mica, mod fr	Fr SS SP SBK					
		44-48	cl f mica, wood fr	Fr NSNP MBK					
4	8% Linear	0-14	sl						PS .35
		14-17	scl						
		17-34	cl mm/f mica						
		34-48	cl f mica						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)		
Site LTAR	.35	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____