DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of
PROPERTY ID #: 106872
COUNTY: 4765-49-8226

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: FLEETWOOD HOMES
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: EVERGREEN LOT 11 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFIL CLASS & LTAR
PIT 1	LSS 10%	0-24"	c l/c, med, SBK, abk	fr, SS, sp, ssp	LOWERED DUE TO LANDSCAPE POSITION	L, T, AR			PS .25
		24-48"	sap inclusions c med. sbk	fr, s, p, ssp					
PIT 2	LSS 10%	0-21"	c, med, SBK abk	fr, s, p, ssp	SAME	SAME			PS .25
		21-48"	sap-like w/ c inclusions	fr, SS, sp, ssp					
WELL 3	LSS 10%	0-36"	C med SBK	fr, s, p, ssp					PS .25
		36-48	sap inclusions C med SBK	fr SS SP SSP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	LP PANEL	LP PANEL
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: P. MITCHELL, C. THOMPSON, COOK DAVIDSON, BRYAN