IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 8/26/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64E., T.R. on Rd #2316 (Bell Rd), T.L. on Pinewood Lane, S/W Corner of Pinewood Lane & Redwood St. S. R. No. _____

SUBDIVISION NAME Cedar Hills LOT NO. 46 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____ Provisional/Suitable

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____


Character & Porosity of Soil CCDS

Percolation Rate 3/4" - 30 min - Mod Severe

Topography 10-15%

Depth to Water Table wet

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Bass & Sale

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 8/26/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold