IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jones Enterprises DATE 8 Feb 77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64 E. & Bell Rd

S. R. No. _____

SUBDIVISION NAME Cedar Hills LOT NO. 92 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	( )	No	(✓)
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 150'x140' approx


Character & Porosity of Soil A, B2

Percolation Rate moderate

Topography 2-6% slope

Depth to Water Table ∞

Rock or other impervious formations ∞



Plot of System Pinewood Lane

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Charlie Poff

IMPROVEMENTS PERMIT BY _____

COMMENTS: 2 separate ditches - 3'x150'

CERTIFICATE OF COMPLETION BY W. M Howard DATE 8 Feb 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold