IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Enterprizes DATE 4-8-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US 64 East TR on Bell Road 300' TL house 400' on corner S. R. No. _____

SUBDIVISION NAME Cedar Hills LOT NO. 33 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 18,645 Sq feet

Character & Porosity of Soil Cecil Clay loam (Porosity Fair)
Percolation Rate 70 min/inch
Topography < 2% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Robert + Bud Hoke

IMPROVEMENTS PERMIT BY W.M. Howard

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 4-8-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold