IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Categanus DATE 8 Feb 77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy 64 E to Bell Rd

S. R. No. _____

SUBDIVISION NAME Cedar Hills LOT NO. 93 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 140' x 140 approx


Character & Porosity of Soil A-1 B-2

Percolation Rate Moderate

Topography 2-6% Slope

Depth to Water Table 2nd

Rock or other impervious formations 2



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by Charlie Poff

IMPROVEMENTS PERMIT BY _____

COMMENTS: 2 bedroom septic tank - 3' x 150'

Needs line shorten because of fill dirt

CERTIFICATE OF COMPLETION BY W M Howard DATE 8 Feb 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold