IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp. DATE 7-14-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. TR on Bell-Rd Mapleleaf Dr.

S. R. No. _____


SUBDIVISION NAME Cedar Hills LOT NO. 59 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Heavy clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	120 min/inch	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6 to 10% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
			Rock or other impervious formations	none	

Lot Area 17,000 Sq feet



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Pfaff + Sales

IMPROVEMENTS PERMIT BY Andrew Causey

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-14-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold