IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis corp DATE 7-14-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E TR on Bell Road mapleleaf Dr. S. R. No. _____

SUBDIVISION NAME Cedar Hills LOT NO. 60 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil CcC3 Heavy Clay
Percolation Rate 120 min/inch
Topography 6 to 10% slope
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 17,000 sq ft



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by P&ASS + Sales

IMPROVEMENTS PERMIT BY Andrew E. Causey

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-14-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold