DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Walter Fox — APPLICANT: Walter Fox
ADDRESS: _____ — APPLICATION DATE: _____ — DATE EVALUATED: 4/25
PROPOSED FACILITY: 3BR MH/Crawl — PROPOSED DESIGN FLOW (.1949): _____ — PROPERTY SIZE: 1.3 Acres
LOCATION OF SITE: Hwy 64 W (1) Right on Rs (2) Rivercrest Drive, (3) Second left #6. — PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed (Lot # 6)

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	Linear 10%	0-7	Scl						PS -3
		7-48	cl						
2	10% Linear	0-6	Scl						PS .3
		6-48	cl						
3	Linear 12%	0-9	Scl						PS .3
		9-38	cl						
		38-4	cl w/ some rock						
		4/+	Rock						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity Conv.	Pump 25%
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson, RSI
OTHER(S) PRESENT: _____