ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Fleetwood Homes APPLICANT: Evelyn Washington

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

PROPOSED FACILITY: 3BR MH/Crawl PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____

LOCATION OF SITE: _____ PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Evergreen Lot #28

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH IN.	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	Linear 4%	0-9" SL 9-23" SCL/Sap 23" Rock							US
2	Linear 3%	0-19" SCL/Sap 19" Rock							US
3	6% Linear	0-7 SCL/Sap SF 7-32 SCL/Sap MF 32-48 Sap SF							US .30
4	7% Linear	0-28 SCL/Sap 28 Sap SF					4S Rock Sap	SCL/Sap Limer Sap Soil	1S .35

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1S	1S
System Type(s)	Gravity 25% Reduction	Pump & 50% Reduction
Site LTAR	.30	.35

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: Bill Robinson

OTHER(S) PRESENT: _____