DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION

Piedmont Realty for ON-SITE WASTEWATER SYSTEM

OWNER: c/o Fleetwood Homes (Carrboro Plant) APPLICANT: Victor Morales
ADDRESS: _____ APPLICATION DATE: 2/9/01 DATE EVALUATED: _____
PROPOSED FACILITY: 4BR MH/Crawl PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: .45
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	2% Linear	0-8	sl						US
		8-20	sc sl						
		20-	sc/sic						
2	2% Linear	0-8	sl						PS .3
		8-20	sc						
		20-32	sc/sic						
		32-48	sic/sc						
3	2% Linear	0-6	U						PS .3
		6-20	sc						
		20-32	sic Some						
		32-48	sic Many						
4		0-6	sl						US
		6-24	sc						
		24-72	sc/sic						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	250% Red Trench	250% Reduction Trench
Site LTAR	.30	.30

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): Bill Lehman
EVALUATED BY: _____
OTHER(S) PRESENT: _____