DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Fleetwood Homes / [illegible] APPLICANT: Richard Smith
ADDRESS: _____ APPLICATION DATE: 1/29/00 DATE EVALUATED: 1/29/01
PROPOSED FACILITY: 3BR MH/Cha PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~61
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Lot # 25

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	Lin 3%	0-9	scl		26"				PS .3
		9-17	cl						
		17-32	C						
		32-36	cl/scl						
		36-48	Sap						
2	Lin 3%	0-7	scl	fr sc sp					PS .3
		7-18	cl msbk	fr sc sp					
		18-28	cl m	fr sc sp					
		28-48	cl/sap m	fr sc sp					
3	Rise 20% Loper	0-4	scl msbk	fr sc sp					PS .3
		4-20	cl msbk	fr sc sp					
		20-22	Sap	—					
		22-48	scl w msbk	fr sc sp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	250 Conv.	500 Reduc.
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Lahman
OTHER(S) PRESENT: _____