IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 3-29-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. TR on Bell Rd, Redwood Dr.

S. R. No. _____


SUBDIVISION NAME Cedar Acres LOT NO. 86 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Fair
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	over
			Rock or other impervious formations	none

Lot Area _____



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Chas. D. Foggs

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 3/29/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold