IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp. DATE 5-16-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 055 Bell Rd

SUBDIVISION NAME Cedar Hills LOT NO. 77 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 16,754 sq'


Character & Porosity of Soil Appling

Percolation Rate 120

Topography 2 to 6 70

Depth to Water Table 10'

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Pfafftsale

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: landscape so that water will not stand over tank or lines

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 5-16-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold