IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Forbis Corp. DATE 10-17-78 PERMIT NO.

PHONE: Business Home

LOCATION 64E TR on Bell Rd

S. R. No.


SUBDIVISION NAME Cedar Hills LOT NO. 32 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Appling + Cecil clays
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	120 min/8 inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6 %
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 18,000 SF



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 700 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Pfass + Sale

Location of the proposed 10'×20' Amish Outbuilding addition does not appear to impact the existing on-site septic system.**NOTE:

REHS
Date: 6-26-12
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 10-17-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy. Gold