IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 5-16-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bell Rd S. R. No. _____

SUBDIVISION NAME Cedar Hills LOT NO. 82 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 15,000 S/F


Character & Porosity of Soil Cecil + Appling

Percolation Rate 100 min/inch

Topography 2 to 4% Slope

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 400 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Pfass + Sale

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: Landscape + Pipe Gutters so water will not stand over Tank or lines.

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 5-16-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold