IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 5-9-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bell Rd

S. R. No. _____


SUBDIVISION NAME Cedar Hills LOT NO. 63 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Appling + cecil clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	120 min/inch +
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6 % Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +
			Rock or other impervious formations	none

Lot Area 15,000 Sq' +



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Pfaff + Sale

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: Grade lot so water will not stand over lines or tank

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 5-9-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold