IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

R OR CONTRACTOR Larry Hickman DATE 11-18-21 PERMIT NO.

E: Business Home

TION 3213 Maple Leaf Dr.

IVISION NAME Cedar Hills LOT NO. 64 SECTION OR BLOCK NO. S. R. No.

Mobile Home ( ) Business ( ) Other Repair

drooms No. Bathrooms


e Disposal Unit Yes ( ) No ( )
Dishwasher Yes ( ) No ( )
Wash. Machine Yes ( ) No ( )
thtub Yes ( ) No ( )

e

Character & Porosity of Soil Clayey
Percolation Rate 1
Topography Level
Depth to Water Table Low
Rock or other impervious formations None

Basement with Plumbing Basement without Plumbing No Basement Crawl

Run brain line engineer



Plot of System

Size of Tank Existing
Nitrification Field:
No. of Lines 1
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines
Water Supply: Individual ( )
Public (x)

12" Sand (screened)

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Larry Hickman

Ditch no deeper than 24"

IVEMENTS PERMIT BY R. C. Weeks

ENTS: Use Sand in drain line instead of stone

FICATE OF COMPLETION BY DATE

NG SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL CURRENT APPLICABLE LAWS AND REGULATIONS

JAN. 5, 1989 17:00