IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Forths Corp DATE 5-9-79 PERMIT NO.

PHONE Business Home

LOCATION Bell Rd

S. R. N.

SUBDIVISION NAME Fortis Corp LOT NO. 64 SECTION OR BLOCK NO.

House ✓ Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½ ✓ Character & Porosity of Soil Appling

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 120 min/inch

Auto. Dishwasher Yes (✓) No ( ) Topography 2 to 6 % Slope

Auto. Wash Machine Yes (✓) No ( ) Depth to Water Table 10'+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations none

Lot Area 15,000 sq' Property line

3' x 140' 3' x 140' 3' x 140'

House

Size of Tank 1000 Gals

Nitrification Field.
No. of Lines 3
Sq. Ft. 1260 Linear Ft. 420
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Pfass + Sale

Plot of System

IMPROVEMENTS PERMIT BY L.C. Moore

COMMENTS Grade lot so water will not stand over Tank or lines.

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 5-9-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

JAN. 4, 1989 17:36