HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: John T. Baker OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	linear	0 to 14	L GR	(0)	PS	PS	PS	PS	.3
		14 to 24	C SBK	SEAP FR to Fi					
		24 to 48	CL WSBK	SEAP FR					
2	linear	0 to 4	L GR		PS	PS	PS	PS	.3
		4 to 24	C SBK	SEAP FR Fi					
		24 to 48	CL WSBK	SEAP FR					
3	flat slope	0 to 4	L GR		U chroma 2	U	U	U	
		4 to 18	C SBK	SEAP Fi					
		18 to 30	C ABK	SAP Fi					
4	linear	0 to 4	L GR		PS chroma 4	unsuitable at 24"			LPP .15
		4 to 24	C SBK	SEAP Fi					
		24 to 36	C ABK	SAP Fi					
5									

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: .3 In
EVALUATED BY: J.C. Simone OTHER(S) PRESENT: John Baker
COMMENTS: area of original System
.15 In Repair