## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John White DATE 7-28-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E TL on River Hill Rd 1mi TR

S. R. No. _____

SUBDIVISION NAME East Iredell Trailer Park LOT NO. 31 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | |
| Auto. Dishwasher | Yes ( ) | No (✓) | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | |
| Site Suitable | Yes (✓) | No ( ) | |

Lot Area ½ acre

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____

Existing System



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines 10
Water Supply: Individual ( )
Public (✓)

Installed by Don Lackey
1972

IMPROVEMENTS PERMIT BY _____

COMMENTS: System is adequate for mobile Home

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-28-78

CONSTRUCTION MUST COMPLY ~~WITH~~ ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold