IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Edwards DATE 8/8/75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64E., T.R at Floyd's Diner, mobile homes at end of Rd

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other 3 mobile homes the used outlet home is built

No. Bedrooms 5 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes ( )	No ( )	

Character & Porosity of Soil Red Clay loam
Percolation Rate _____
Topography slope to front
Depth to Water Table unk.
Rock or other impervious formations none found

Lot Area 3 acres



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Sigmon

IMPROVEMENTS PERMIT BY _____

COMMENTS: Mobile home to be Taken off before home is inhabited

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 8/8/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold