IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 204040

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4765805794

APPLICANT: Bruce Porter APPLICANT ADDRESS: 2143 Mocksville Hwy

SITE ADDRESS: 254 Lone Pine Rd. PHONE: 704-902-3124 ALT. PHONE: N/A


SITE DIRECTIONS: Hwy 64 E TR Lone Pine Rd.

SUBDIVISION: Lone Pine Meadows SECTION: 2 LOT # 7 LOT AREA: 0.49 acres DESIGN FLOW: 360gpd L.T.A.R.: 0.25

Septic Tank	1000 (gal)	STB	1600 - 1000	Date	8-14-14	☑ New System ☐ Repair ☐ Expansion	System Type: I II ☒ III IV V VI	☑ Residence	No. Bedrooms	3	Water Supply
Pump Tank	(gal)	PT		Date		System Description:	25% Reduction	☐ Business	No. Persons	6	☐ Private
Pump Make		Model		Serial #		Repair System Description:	50% Reduction	☐ Other	No. Employees		☑ Public
# Nitrification Fields	1	# Lines	5	Linear Ft:	360	Maintenance Agreement Required:	☐ YES ☑ NO	☐ Slab	☑ Crawl Space		☐ Community
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth	N/A	☑ GRAVITY	☐ PRESSURE	☐ Basement w/plumbing			☐ Basement w/o plumbing

Comments / Conditions: Install a 25% Reduction system on contour with serial distribution. Do NOT Cut for house sites

INITIAL SITE SKETCH



AS

- 12" Polylok filter installed
- 2" PVC SI marker installed
- Quick Chambers installed as drawn
- H installed

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Bruce Porter Date: 7-15-14 Installed by: Cothran & Son

IMPROVEMENT PERMIT by: Justin Henderson Date: 7-15-14 OPERATION PERMIT by: Justin Henderson Date: 10-9-14

AUTHORIZATION TO CONSTRUCT by: Justin Henderson Date: 7-15-14 Existing System Inspected by: Date: