* Repair

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # Repair PIN # 4765-93-2682 DATE 9 July 09

OWNER or APPLICANT Clyde & Janice Reavis PHONE: Business Home: (704) 880-2812

OWNER or APPLICANT ADDRESS 108 Warren Rd. Statesville, NC.

LOCATION / DIRECTIONS Hwy 64E To Warren Rd. ON Rt. in corner.

SUBDIVISION BLOCK / SECTION LOT # LOT AREA 1.38ac. DESIGN FLOW 240gpd. L.T.A.R. 0.3g/ft²/d

Septic Tank 1000 Gallons: STB 1000 Date 4-8-08

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 2 Linear Feet 200'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth

☐ New System ☑ Repair ☐ Expansion System Type I II III IV V VI

System Description: 2590 Reduction System

Repair System Description:

Maintenance Agreement Required ☐ YES ☑ NO

☐ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 2 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply ☑ Private ☑ Public ☐ Community

Comments / Conditions * Connect washing machine drain into New septic system. * Honor all setback requirements. * Properly Abandon old septic tank.

Comments / Conditions

Read Jed Fite

INITIAL SITE SKETCH

* Please see Attached Site sketch.

AS BUILT SKETCH

Risers up to 6" @ grade

Septic main

Tank 34" Deep

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☑ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Janice D. Reavis Date 7/10/09

Improvement Permit by: Date

Authorization to Construct by: Jim Haggard, R.S. Date 9 July 09

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: David D. Yelton

Operation Permit by: Date: 4-15-09

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant


4765-93-3836
300
4765-94-5030
158
200
258
4765-84-7036
WARREN RD
2200
existing well
4765-93-2682
300
Existing 2 BR House
300
4765-93-4692
OE
IM
Wash machine drain
Route to septic tank
Fuel
New 1000 gal ST
100'
100'
9'
200
257
5)
N
W
E
S
MOCKSVILLE HWY
1 inch = 50 feet