DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet ____ *of* ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Clyde Reaves — APPLICATION DATE _____
ADDRESS: 10X Warren Rd. — DATE EVALUATED: 8-6-07
PROPOSED FACILITY: Rpr 2bd Home — PROPOSED DESIGN FLOW (.1949): 2 bdrm — PROPERTY SIZE: _____
LOCATION OF SITE: Hwy 64E @ TL Warrenton - 2nd Rt. in Comm. — PROPERTY RECORDED: _____
WATER SUPPLY: •/Private • /Public • Well • Spring • Other _____
EVALUATION METHOD: •/Auger Boring • Pit • Cut — TYPE OF WASTEWATER: •/Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 6%	0-9	mixed fill	compacted	7-18	>18	—	—	PS 0.7
		9-48+	SBK/SG	fr/sap					
2	L 6%N	0-5	mixed fill	compacted	7-18	>18	—	—	PS 0.7
		5-14	SBK/SCL	fr/sap					
		14-48+	SBK/SC	fr/sap					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		PS
System Type(s)		TL Rpr
Site LTAR		0.7

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: TLL
OTHER(S) PRESENT: _____

COMMENTS: _____