DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: TRIPLE OAKS APPLICANT: _____
ADDRESS: ~~BRADFORD RD~~ LOT 2 APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed FRENCH DRAIN

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	40% L	0-3"	scl, wk, gr	fr, ns, np, vscp					
		3-12"	cl, med, sbk	fi, ss, sp, sscp		748"			PS .3
		12-18"	cl, med, abk/sbk	fr, ss, sp, sscp	chroma 3-4				
		18-36"	c, med, sbk	fr, ss, sp, sscp					
2	40% L	0-3"	scl, wk, gr	fr, ns, np, vscp					
		3-12"	cl, med, sbk	fi, ss, sp, sscp					
		12-18"	cl, med, abk/sbk	fr, ss, sp, sscp	chroma 3-4	748"			PS .3
		18-36"	c, med, sbk	fr, ss, sp, sscp					
3	40% L	0-3"	scl wk gr	fr, ns, np, vscp					
		3-12"	cl med sbk	fi, ss, sp, sscp					
		12-18"	cl med abk/sbk	fr, ss, sp, sscp	chroma 3-4	745"			PS .3
		18-36"	c med, sbk	fr, ss, sp, sscp					
4	40% L	0-3"	scl, wk, gr	fr, ns, np, vscp					
		3-12"	cl, med, sbk	fi, ss, sp, sscp					
		12-48"	c, med, sbk	fr, ss, sp, sscp		748"			PS .3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	6 CAN 25% Red	LP PANEL
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COLK
OTHER(S) PRESENT: _____